



**GENERAL NOTES**

- REFER TO E4.0 FOR ONE LINE DIAGRAM AND E5.0 FOR PANEL SCHEDULES. REFER TO E7.0 FOR SPECIFICATIONS, NOTES, LIGHTING SCHEDULE, AND SYMBOLS.
- SUBSCRIPT INDICATES CIRCUIT NUMBER, IE:  
 ● HA3 HA3 INDICATES CIRCUIT NO. 3 PANEL HA  
 ● HB3 HB3 INDICATES CIRCUIT NO. 3 PANEL HB  
 ● LB3 LB3 INDICATES CIRCUIT NO. 3 PANEL LB
- PROVIDE 30/3/NF NEMA 3R SAFETY SWITCHES ON 3-TON, 4-TON, & 5-TON RTU'S.

REVISIONS AND ISSUANCE		
NO.	DATE	DESCRIPTION
1	08/13/2018	PRICING

**IVY KIDS EARLY LEARNING CENTER**  
 4434 CR 94  
 Manvel, Tx 77578

MEP Consultants  
 BLK Engineering & Consulting Co.  
 3423 Spring Arbor Ln.  
 Sugar Land, TX 77479  
 (t) 832 563 3127  
 TBPE Firm #12672

THESE DOCUMENTS ARE  
 FOR INTERIM REVIEW AND NOT  
 FOR CONSTRUCTION, BIDDING  
 OR PERMIT PURPOSES.  
 RESPONSIBLE ENGINEER:  
 CHH-TAI KENG  
 79201  
 08-13-2018

DRAWING TITLE  
**HVAC  
 POWER PLAN**

DRAWN BY FK	CHECKED BY CK
DATE 05/10/2018	JOB NO. SEDONA LAKES
DRAWING NO. <b>E-3.1</b>	

**1 HVAC POWER PLAN**  
 1/8" = 1'-0"